

AVAILABLE TRANSMISSION CAPACITY

Connection Point/Voltage Level	Available Transmission Capacity for the Special Auction Round for WTE, Cumulative MW (as of January 2026)		
	2027	2028	2029
LUZON	3,034	3,134	4,334
I. Existing	2,224	2,224	2,224
Tap to Bauang-San Fabian 69 kV Line	40	40	40
Bacnotan 69 kV SS	60	60	60
Tap to La Trinidad-Sagada 69 kV Line	60	60	60
Tap to San Manuel-Calasiao 69 kV Line	80	80	80
Tap to Nagsaag-Umingan 69 kV Line	40	40	40
Tap to Labrador-San Carlos 69 kV Line	40	40	40
Tap to Labrador-Bani 69 kV Line	40	40	40
Balingueo 230 kV S/S	60	60	60
Balsik 230 kV S/S	300	300	300
Mariveles (Alas-asin) 500 kV S/S	584	584	584
Tap to Mexico-Calumpit 69 kV Line	40	40	40
Tap to Mexico-Apalit 69 kV Line	90	90	90
Tap to Cabanatuan-San Luis 69 kV Line	40	40	40
San Jose 230 kV S/S	400	400	400
Tap to Batangas-Rosario 69 kV Line	40	40	40
Tap to Batangas-Mabini-Cuenca 69 kV Line	40	40	40
Tap to Bay-Calamba 69 kV Line	40	40	40
Tap to Gumaca-Pitogo-Mulanay 69 kV Line	40	40	40
Labo 69 kV S/S	0	0	0
Tap to Tiwi C-Malinao 69 kV Line	30	30	30
Tap to Daraga-Irosin 69 kV Line	40	40	40
Tap to Daraga-Ligao 69 kV Line	40	40	40
Tap to Naga-Iriga 69 kV Line	40	40	40
Tap to Daraga-Sto. Domingo 69 kV Line	40	40	40
II. Proposed	810	910	2,110
Balaoan 500 kV SS	0	0	0
Laoag 500/230 kV SS	0	0	0

Castillejos 230 kV S/S	190	460	460
Porac 230 kV S/S	0	0	300
Tuy 230 kV S/S	620	450	450
Milaor 500 kV S/S	0	0	900
Sta. Maria 500 kV S/S	0	0	0

Connection Point/Voltage Level	Available Transmission Capacity for the Special Auction Round for WTE, Cumulative MW (as of January 2026)		
	2027	2028	2029
VISAYAS	810	810	2,192
I. Existing	120	120	1,502
Dumanjug 230 kV S/S	0	0	300
Dumanjug 69 kV S/S	0	0	90
Toledo 138 kV S/S	0	0	40
Naga 138 kV S/S	0	0	150
Tap to Calong-calong-Asturias 69 kV T/L	40	40	40
Corella 230 kV S/S	0	0	600
Corella 138kV S/S	0	0	150
Corella 69 kV S/S	0	0	52
Ubay 138 kV S/S	0	0	0
Tap to Corella-Tagbilaran 69 kV T/L	40	40	40
Tap to Corella-Maribojoc 69 kV T/L	40	40	40
II. Proposed	690	690	690
Tominjao 230 kV SWS	0	0	0
Umapad 230 kV S/S	600	600	600
Umapad 69 kV S/S	90	90	90
Bonbon 230 kV SWS	0	0	0

Connection Point/Voltage Level	Available Transmission Capacity for the Special Auction Round for WTE, Cumulative MW (as of January 2026)		
	2027	2028	2029
MINDANAO	3,240	3,240	3,240
I. Existing	2,640	2,640	2,640
Polanco–Roxas 69 kV Transmission Line	40	40	40
Tap to Aurora-Calamba 69 kV Line	40	40	40
Tap to Aurora-San Miguel 69 kV Line	40	40	40
Tap to Zamboanga-Tumaga 69 kV Line	40	40	40
Aurora 69 kV SS	20	20	20
Pitogo 69 kV SS	40	40	40
Zamboanga 69 kV SS	20	20	20
Tap to Agus 6-Kauswagan 69 kV Line	20	20	20
Lala 230 kV SS	300	300	300
Balo-i 230 kV SS	150	150	150
Balo-I 69 kV SS	40	40	40
Tap to Jasaan-Balingasag 69 kV Line	40	40	40
Maramag 230 kV SS	300	300	300
Villanueva 230 kV SS	150	150	150
Opol 138 kV SS	50	50	50
Jasaan 138 kV SS	100	100	100
Kibawe 138 kV SS	100	100	100
Manolo Fortich 69 kV SS	40	40	40
Opol 69 kV SS	40	40	40
Tagoloan 69 kV SS	40	40	40
Maramag 69 kV SS	40	40	40
Placer 138 kV SS	70	70	70
San Francisco 138 kV SS	150	150	150
San Francisco 69 kV SS	40	40	40
Tap to Nabunturan-Asuncion 69 kV Line	40	40	40
Tap to Nabunturan-Compostela 69 kV Line	40	40	40
Tap to Maco-Banaybanay 69 kV Line	40	40	40
Tap to Maco-Tagum 69 kV Line	40	40	40
Toril 230 kV SS	300	300	300
Maramag 69 kV SS	40	40	40
Davao 69 kV SS	40	40	40

Bunawan 69 kV SS	40	40	40
Tap to Sultan Kudarat-Datu Saudi Ampatuan 69 kV Line	40	40	40
Tap to Tacurong-Salbu 69 kV Line	40	40	40
Tacurong 138kV SS	20	20	20

Connection Point/Voltage Level	Available Transmission Capacity for the Special Auction Round for WTE, Cumulative MW (as of January 2026)		
	2027	2028	2029
Tap to Tacurong-Kalamansig 69 kV SS Line	50	50	50
II. Proposed	600	600	600
Laguindingan 230 kV SS	300	300	300
Kabacan 138 kV SS	150	150	150
Koronadal 138 kV SS	0	0	0
Tago 138 kV SS	150	150	150
Mati 69 kV SS	0	0	0
Mati 138 kV SS	0	0	0